

NOTE: Azimuth Position vs Accuracy graphs are accurate to within 0.5 degrees. The accuracy shown in the potentiometer deadband region between 355 and 0 degrees is the result of no resistance change while position changes. The gap represents the actual deadband (open circuit).



R.M. Young Company 2801 Aero Park Drive Traverse City, Michigan 49686 USA



CALIBRATION REPORT Wind Speed

Customer:

University of Hawaii

Test Number: 3128-02W Test Date: 28 January 2013 Customer PO: Z10020870

Sales Order: 3142

Test Sen	SOT:		
Anemometer: 05106 Wind Monitor	Propeller:	08234	
Serial Number: WM43393	Serial Number:	51153	

Report of calibration comparison with National Institute of Standards and Technology calibrated anemometer in the R.M. Young Company 50 x 75 cm rectangular test section open return wind tunnel. The following data describe the relationship between test section wind speed, as determined by the NIST calibrated standard anemometer, and test anemometer rpm, as determined by its output. Indicated wind speed is calculated using anemometer's published formula.

Wind Speed According to Standard Anemometer		Wind Speed According to Test Anemometer			
Model: Serial #:	05103 / 08234 00005	Anem: Serial #:	05106 WM43393	Prop: 08234 Serial # 51153	
Nominal	Actual	100 Second	Output	Propeller	Indicated
Speed m/s	Speed m/s (1)	Pulse Count	Frequency	/ RPM (2)	Speed m/s (3)
30	30.0	30874	308.7	6175	30.3
25	25.0	25717	257.2	5143	25.2
20	20.0	20508	205.1	4102	20.1
16	16.0	16349	163.5	3270	16.0
14	14.0	14290	142.9	2858	14.0
12	12.0	12225	122.3	2445	12.0
10	10.0	10166	101.7	2033	10.0
8	8.0	8088	80.9	1618	7.9
6	6.0	6044	60.4	1209	5.9
5	5.0	5008	50.1	1002	4.9
4	4.0	3992	39.9	798	3.9
3	3.0	2978	29.8	596	2.9
2	2.1	1921	19.2	384	1.9
1	1.1	866	8.7	173	0.8
National Insti	tute of Standards and Te	echnology Refe	erence	Environmental Conditions	
	andard Anemometer (4)			Barometric Pressure (hPa):	986
Test #:	TN251034			Temperature (C):	23.0
Date:	9 Nov 1992			Relative Humidity (%):	48.0

 Date:
 9 Nov 1992

 Model:
 08234
 Serial #:
 00005

(1) Actual wind speed determined by relationship between tunnel fan rpm and NIST calibrated standard

propeller rpm. (2) Wind Monitor output is three (3) pulses per revolution: $Rpm = Hz / 3 \times 60$ sec.

(3) Published calibration: Wind speed (m/s) = 0.00490 x propeller rpm.

(4) NIST Calibration accuracy is within 1%.

Tested By

1le

M E T E O R O L O G I C A L I N S T R U M E N T S Tel: 231-946-3980 Fax: 231-946-4772 Email: met.sales@youngusa.com Website: youngusa.com ISO 9001:2008 CERTIFIED



R.M. Young Company 2801 Aero Park Drive Traverse City, Michigan 49686 USA

CALIBRATION REPORT

Wind Speed (page 2)

Test Number: 3128-02W

Linear Regression

A linear regression is performed on the calibration data to determine the best fit straight line representing the relationship between propeller rpm and actual wind speed as determined by the NIST calibrated standard anemometer.

Intercept: 0.19 meters per second Pitch: 28.94 centimeters per revolution Correlation Coefficient: 0.99999	
Wind Speed = Slope x RPM + Intercept Slope x H	+ Intercept
m/s = 0.00482 x RPM + 0.19 0.09646 x H	2 + 0.19
mph = 0.01079 x RPM + 0.42 0.21578 x H	2 + 0.42
knots = 0.00937 x RPM + 0.36 0.18738 x H	2 + 0.36
km/hr = 0.01736 x RPM + 0.67 0.34726 x H	2 + 0.67

Threshold Measurements

	New Instrument	As Found	As Left	
Start:		0.4 m/s	0.5 m/s	
	n/a			
Stop:		0.2 m/s	0.4 m/s	

M E T E O R O L O G I C A L I N S T R U M E N T S Tel: 231-946-3980 Fax: 231-946-4772 Email: met.sales@youngusa.com Website: youngusa.com ISO 9001:2008 CERTIFIED