


PO Box 518
620 Applegate St.
Philomath, OR 97370



(541) 929-5650
Fax (541) 929-5277
www.wetlabs.com

C-Star Calibration

Date July 24, 2007

Customer University of Hawaii

Work order 001

Job # 0707014

S/N# CST-1034DR

Pathlength 25 cm

	Analog output	Digital output
V_d	0.063 V	65 counts
V_{air}	4.755 V	3950 counts
V_{ref}	4.657 V	3869 counts

Temperature of calibration water

24.5 °C

Ambient temperature during calibration

26.3 °C

Relationship of transmittance (Tr) to beam attenuation coefficient (c), and pathlength (x): $Tr = e^{-cx}$

To determine beam transmittance: $Tr = (V_{sig} - V_{dark}) / (V_{ref} - V_{dark})$

To determine beam attenuation coefficient: $c = -1/x * \ln(Tr)$

V_d Meter output with the beam blocked. This is the offset.

V_{air} Meter output in air with a clear beam path.

V_{ref} Meter output with clean water in the path.

Temperature of calibration water: temperature of clean water used to obtain V_{ref} .

Ambient temperature: meter temperature in air during the calibration.

V_{sig} Measured signal output of meter.